

technical basis for these estimates must be provided.

(5) If you produce soda ash using the liquid alkaline feedstock process and use the site-specific emission factor method to estimate emissions (§ 98.293(b)(3)) then you must also retain the following relevant information:

(i) Records of performance test results.

(ii) You must document the procedures used to ensure the accuracy of the annual average vent flow measurements including, but not limited to, calibration of flow rate meters and other measurement devices. The estimated accuracy of measurements made with these devices must also be recorded, and the technical basis for these estimates must be provided.

§ 98.298 Definitions.

All terms used in this subpart have the same meaning given in the Clean Air Act and subpart A of this part.

Subpart DD—Electrical Transmission and Distribution Equipment Use

SOURCE: 75 FR 74855, Dec. 1, 2010, unless otherwise noted.

§ 98.300 Definition of the source category.

(a) The electrical transmission and distribution equipment use source category consists of all electric transmission and distribution equipment and servicing inventory insulated with or containing sulfur hexafluoride (SF₆) or perfluorocarbons (PFCs) used within an electric power system. Electric transmission and distribution equipment and servicing inventory includes, but is not limited to:

- (1) Gas-insulated substations.
- (2) Circuit breakers.
- (3) Switchgear, including closed-pressure and hermetically sealed-pressure switchgear and gas-insulated lines containing SF₆ or PFCs.
- (4) Gas containers such as pressurized cylinders.

(5) Gas carts.

(6) Electric power transformers.

(7) Other containers of SF₆ or PFC.

§ 98.301 Reporting threshold.

(a) You must report GHG emissions from an electric power system if the total nameplate capacity of SF₆ and PFC containing equipment (excluding hermetically sealed-pressure equipment) located within the facility, when added to the total nameplate capacity of SF₆ and PFC containing equipment (excluding hermetically sealed-pressure equipment) that is not located within the facility but is under common ownership or control, exceeds 17,820 pounds and the facility meets the requirements of § 98.2(a)(1).

(b) A facility other than an electric power system that is subject to this part because of emissions from any other source category listed in Table A-3 or A-4 in subpart A of this part is not required to report emissions under subpart DD of this part unless the total nameplate capacity of SF₆ and PFC containing equipment located within that facility exceeds 17,820 pounds.

§ 98.302 GHGs to report.

You must report total SF₆ and PFC emissions from your facility (including emissions from fugitive equipment leaks, installation, servicing, equipment decommissioning and disposal, and from storage cylinders) resulting from the transmission and distribution servicing inventory and equipment listed in § 98.300(a). For acquisitions of equipment containing or insulated with SF₆ or PFCs, you must report emissions from the equipment after the title to the equipment is transferred to the electric power transmission or distribution entity.

§ 98.303 Calculating GHG emissions.

(a) Calculate the annual SF₆ and PFC emissions using the mass-balance approach in Equation DD-1 of this section: